

CERTIFICATE

No. Z2 18 05 72092 277



Product Service

Holder of Certificate: Shanghai JA Solar Technology Co., Ltd.

No. 118, Lane 3111,
West Huancheng Road
Fengxian District
201401 Shanghai
PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061604126-07

Valid until: 2023-05-06



Date, 2018-05-11

(Zhulin Zhang)

Page 1 of 3

CERTIFICATE

No. Z2 18 05 72092 277



Product Service

Model(s):

JAP6(K)-72-xxx/4BB/1500V, JAP72D00-xxx/SC
xxx = 310 to 330 in step of 5;
JAP6(K)-60-xxx/4BB/1500V, xxx = 255 to 275 in step of 5;
JAP60D00-xxx/SC, xxx = 260 to 270 in step of 5;
JAP72D00-xxx/PR, xxx = 330 to 345 in step of 5;
JAP60D00-xxx/PR, xxx = 275 to 290 in step of 5;
JAP6(K)-72-xxx/4BB, xxx = 310 to 330 in step of 5;
JAP6(K)-60-xxx/4BB, xxx = 255 to 275 in step of 5;
JAP72S01-xxx/SC, xxx = 310 to 335 in step of 5;
JAP60S01-xxx/SC, xxx = 255 to 280 in step of 5;
JAP72S01-xxx/PR, xxx = 330 to 345 in step of 5;
JAP60S01-xxx/PR, xxx = 275 to 285 in step of 5;
JAP72S03-xxx/SC, xxx = 320 to 345 in step of 5;
JAP60S03-xxx/SC, xxx = 270 to 290 in step of 5;
xxx is standing for rated output power at STC

Parameters:

| | |
|----------------------------|--|
| Rated Output Power at STC: | See the attachment |
| Construction: | Framed or Frameless, with Junction box, Cable and Connectors. |
| Test Laboratory: | Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China |
| Safety Class: | Class II |
| Maximum System Voltage: | 1500 V DC or 1000 V DC |
| Fire Safety Class: | Class C or Class A according to UL790 |

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)

Production Facility(ies):

72092, 79395, 72056, 90968, 95903, 97323, 01112

CERTIFICATE

No. Z2 18 05 72092 277



Product Service

The following models will be covered by above certificate:

| System voltage:1500 V DC | | |
|--|---------------------------------------|-------------------|
| Model | Rated Output Power at STC | Fire Safety Class |
| JAP6(K)-72-xxx/4BB/1500V, xxx= 310 to 330 in step of 5; | 310 W, 315 W, 320 W, 325 W, 330 W; | Class C |
| JAP6(K)-60-xxx/4BB/1500V, xxx= 255 to 275 in step of 5; | 255 W, 260 W, 265 W, 270 W, 275 W; | |
| JAP60D00-xxx/SC, xxx= 260 to 270 in step of 5; | 260 W, 265 W, 270 W; | Class A |
| JAP72D00-xxx/SC, xxx= 310 to 330 in step of 5; | 310 W, 315 W, 320 W, 325 W, 330 W; | |
| JAP72D00-xxx/PR, xxx= 330 to 345 in step of 5; | 330 W, 335 W, 340 W, 345 W; | |
| JAP60D00-xxx/PR, xxx= 275 to 290 in step of 5; | 275 W, 280 W, 285 W, 290 W; | |

| System voltage:1000 V DC | | |
|--|---------------------------------------|-------------------|
| Model | Rated Output Power at STC | Fire Safety Class |
| JAP6(K)-72-xxx/4BB, xxx= 310 to 330 in step of 5; | 310 W, 315 W, 320 W, 325 W, 330 W; | Class C |
| JAP6(K)-60-xxx/4BB, xxx= 255 to 275 in step of 5; | 255 W, 260 W, 265 W, 270 W, 275 W; | |

| System voltage:1000 or 1500 V DC | | |
|--|--|-------------------|
| Model | Rated Output Power at STC | Fire Safety Class |
| JAP72S01-xxxSC, xxx= 310 to 335 in step of 5; | 310 W, 315 W, 320 W, 325 W, 330 W, 335 W; | Class C |
| JAP60S01-xxx/SC, xxx= 255 to 280 in step of 5; | 255 W, 260 W, 265 W, 270 W, 275 W, 280 W; | |
| JAP72S01-xxx/PR, xxx= 330 to 345 in step of 5; | 330 W, 335 W, 340 W, 345 W; | |
| JAP60S01-xxx/PR, xxx= 275 to 285 in step of 5; | 275 W, 280 W, 285 W; | |
| JAP72S03-xxx/SC, xxx =320 to 345, in step of 5; | 320 W, 325 W, 330 W, 335 W, 340 W, 345 W; | |
| JAP60S03-xxx/SC, xxx =270 to 290, in step of 5; | 270 W, 275 W, 280 W, 285 W, 290 W; | |