



Product Service

# CERTIFICATE


No. Z2 17 07 99333 010

**Holder of Certificate:** LONGi Green Energy Technology Co., Ltd.

No. 388, Middle Hangtian Road  
 Chang'an District  
 710100 Xi'an City, Shaanxi  
 PEOPLE'S REPUBLIC OF CHINA



**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
 Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704061601016-01

**Valid until:** 2022-07-20



**Date,** 2017-07-31

( Zhulin Zhang )

Page 1 of 2



**CERTIFICATE**

No. Z2 17 07 99333 010

**Model(s):**

LR6-72-xxxM, (xxx=320 to 350 in step of 5)  
 LR6-60-xxxM, (xxx=270 to 300 in step of 5)  
 LR6-72PE-xxxM, (xxx=340 to 375 in step of 5)  
 LR6-60PE-xxxM, (xxx=280 to 310 in step of 5)  
 xxx is standing for rated output power at STC

**Parameters:**

Rated Output Power at STC:	320 W, 325 W, 330 W, 335 W, 340 W, 345 W, 350 W, 270 W, 275 W, 280 W, 285 W, 290 W, 295 W, 300 W, 340 W, 345 W, 350 W, 355 W, 360 W, 365 W, 370 W, 375 W, 280 W, 285 W, 290 W, 295 W, 300 W, 305 W, 310 W.
Severity of Salt Mist Test:	Severity 1
Application Class:	Class A
Maximum System Voltage:	1000 V DC
Fire Safety Class:	Class C
Construction:	Framed, with Junction box, Cable and Connectors.

**Tested according to:**

IEC 61215(ed.2)  
 IEC 61730-1(ed.1);am1;am2  
 IEC 61730-2(ed.1);am1  
 IEC 61701(ed.2)

**Production Facility(ies):**

99605, 99606, 99626, 90968, 01192